



NOTICE:
THE DISTRICT MAY REQUIRE REVISED PIPING LAYOUT TO ACCOMMODATE A DISTRICT REQUIRED AND APPROVED FLOW METERING DEVICE WITH LOCAL READOUT AND REMOTE SCADA/RTU MONITORING.

- NOTICE:**
1. SEE DISTRICT STANDARDS SECTIONS 11,12 & 13 FOR ADDITIONAL REQUIREMENTS
 2. PIPING LAYOUT INDICATED IS TYPICAL FOR 4" AND 6" DIA. STATION PIPING. LARGER STATIONS WITH 8" DIA. AND LARGER PIPING SHALL BE SUBJECT TO DISTRICT PRELIMINARY DESIGN REVIEW.
 3. ALL ELECTRICAL EQUIPMENT AND APPURTENANCES LOCATED BELOW 1.25 FEET ABOVE THE BASE FEMA FLOOD ELEVATION SHALL BE NEMA 6X.

JAMES ISLAND PUBLIC SERVICE DISTRICT	
TYPICAL PUMP STATION SECTION	DRAWING: 15
DATE: 05/24/16	DRAWN BY: GRG & ASSOC., INC
SCALE: NTS	APPROVED BY: DJH