



NOTICE:
ALL FABRIC SHALL BE BLACK VINYL COATED; ALL POSTS, PIPE RAILS AND APPURTENANCES SHALL BE BLACK VINYL COATED TO MATCH FABRIC

FENCING SPECIFICATIONS:

1. ALL FENCE MATERIAL SHALL BE CLASS I GALVANIZED COATED.
2. FABRIC SHALL BE 6 FEET HIGH, ENDS BARBED, COMMERCIAL GRADE 9 GAUGE, 2" MESH WITH BLACK VINYL COATED FABRIC EXCEPT AS NOTED ON PLAN VIEWS.
3. END, CORNER, PULL POSTS, AND ACCESSORIES SHALL GALVANIZED, BLACK VINYL COATED TO MATCH FABRIC.
4. TOP RAIL, CORNER AND LINE POSTS SHALL BE SIZED AS SPECIFIED, GALVANIZED COATED, AND VINYL COATED TO MATCH FABRIC.
5. BOTTOM TENSION WIRE SHALL BE 7 GAUGE SPRING COIL WIRE WITH GREEN VINYL OR GALVANIZED COATING AND PAINTED TO MATCH FABRIC.
6. BARB WIRE SHALL BE 12.5 GAUGE GALVANIZED BARB; 14 GAUGE FOUR POINT PATTERN ON 5 INCHES CENTERS, THREE (3) ROWS OF OUTWARD FACING BARBED WIRE SHALL BE USED.
7. GATE POSTS SHALL BE AS SPECIFIED UNLESS INDICATED OTHERWISE.
8. GATE SHALL BE OF THE WIDTH AND TYPE (SINGLE OR DOUBLE) AND AT THE LOCATIONS INDICATED. GATE SHALL BE EQUIPPED WITH A PROP POST CENTER LATCH AND HASP ASSEMBLY. A GROUND ANCHOR CAST IN CONCRETE SHALL BE PROVIDED. GATE SHALL BE FACTORY FABRICATED AND EQUIPPED WITH GATE HOLDERS. ALL GATE MATERIALS SHALL BE PAINTED TO MATCH BLACK VINYL FABRIC.
9. 4' EMPLOYEE ENTRANCE GATE SHALL BE INSTALLED ADJACENT TO 16' VEHICLE GATE
10. VEHICLE GATE TO BE CENTERED WITH WETWELL OPENING.

JAMES ISLAND PUBLIC SERVICE DISTRICT

OPTIONAL CHAIN LINK
PUMP STATION FENCE

DRAWING:

18

DATE: 05/24/16

DRAWN BY: GRC & ASSOC., INC

SCALE: NTS

APPROVED BY: DJH