



NOTES:

1. ALL WOOD SHALL BE PRESSURE TREATED.
2. ALL HARDWARE SHALL BE GALVANIZED.
3. ALL CORNER POSTS, LINE POSTS AND GATE POSTS SHALL BE SET IN 3000psi CONCRETE FOOTINGS AS SHOWN.
4. GATE SHALL BE EQUIPPED WITH A PROP POST CENTER LATCH AND HASP ASSEMBLY. A GROUND ANCHOR CAST IN CONCRETE SHALL BE PROVIDED.
5. 4' EMPLOYEE ENTRANCE GATE SHALL BE INSTALLED ADJACENT TO 16' VEHICLE GATE.
6. VEHICLE GATE TO BE CENTERED WITH WETWELL OPENING.

**JAMES ISLAND
PUBLIC SERVICE DISTRICT**

TYPICAL PUMP STATION FENCE
WOODEN FENCE

DRAWING:

17

DATE: 05/24/16

DRAWN BY: GRG & ASSOC., INC

SCALE: NTS

APPROVED BY: DJH